



PRODUCT-DETAILS

XT2V 160 Ekip Dip LS/I In=10A 3p F F

XT2V 160 Ekip Dip LS/I In=10A 3p F F



General Information	
Extended Product Type	XT2V 160 Ekip Dip LS/I In=10A 3p F F
Product ID	1SDA067971R1
EAN	8015644018672
Catalog Description	XT2V 160 Ekip Dip LS/I In=10A 3p F F
Long Description	C.BREAKER TMAX XT2V 160 FIXED THREE-POLE WITH FRONT TERMINALS AND SOLID-STATE RELEASE IN AC EKIP DIP LS/I R 10 A

ABB EcoSolutions	
ABB EcoSolutions	Yes
ABB Site Meeting Group Waste To Landfill Target	UL 2799 Zero Waste To Landfill Validation available
End Of Life Disassembling Instructions	9AKK108468A2349
Environmental Product Declaration - EPD	9AKK108469A1855 9AKK108468A1897
Recyclability Rate of the Product acc. to EN45555	Design for Closing Resource Loops - Standard EN45555 - 55.70 %

Material Compliance

REACH Declaration	9AKK108466A1425
RoHS Information	9AKK108466A1424
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
Toxic Substances Control Act - TSCA	9AKK108467A8326

Environmental

Environmental Information	9AKK108467A6707
---------------------------	-----------------

Ordering

Order Code US and Canada	XT2VE3010EFF000XXX
E-Number (Norway)	4379466
EAN	8015644018672
Minimum Order Quantity	1 piece
Customs Tariff Number	85362090

Dimensions

Product Net Width	90 mm
Product Net Height	130 mm
Product Net Depth / Length	82.5 mm
Product Net Weight	1.12 kg

Container Information

Package Level 1 Units	box 1 piece
Package Level 1 Width	131 mm
Package Level 1 Height	212 mm
Package Level 1 Depth / Length	147 mm
Package Level 1 Gross Weight	1.22 kg
Package Level 1 EAN	8015644018672

Additional Information

Circuit Breaker Type to be Associated	Power Distribution
Product Main Type	SACE Tmax XT
Product Name	Moulded Case Circuit Breaker
Product Type	Automatic Circuit Breaker
Version	F

CAD Dimensional
Drawing

1SDH002230A1001

Technical

Connecting Capacity Main Circuit	Busbar 32.5..100 mm ²
Current Type	AC
Electrical Durability	120 cycles per hour 8000 cycle
Mechanical Durability	240 cycles per hour 25000 cycle
Number of Poles	3P
Opening Time	CB with SOR 30 ms CB with UVR 30 ms
Order Multiple	1 piece
Power Loss	at Rated Operating Conditions per Pole 0.1 W
Rated Current (I _n)	10 A
Rated Frequency (f)	50 / 60 Hz
Rated Impulse Withstand Voltage (U _{imp})	8 kV
Rated Insulation Voltage (U _i)	1000 V
Rated Operational Voltage	690 V AC
Rated Service Short- Circuit Breaking Capacity (I _{cs})	(220 V AC) 200 kA (230 V AC) 200 kA (240 V AC) 200 kA (380 V AC) 150 kA (415 V AC) 150 kA (440 V AC) 150 kA (500 V AC) 70 kA (525 V AC) 50 kA (690 V AC) 15 kA
Rated Ultimate Short- Circuit Breaking Capacity (I _{cu})	(220 V AC) 200 kA (230 V AC) 200 kA (240 V AC) 200 kA (380 V AC) 150 kA (415 V AC) 150 kA (440 V AC) 150 kA (500 V AC) 70 kA (525 V AC) 50 kA (690 V AC) 20 kA
Rated Uninterrupted Current (I _u)	160 A
Rated Voltage (U _r)	690 V
Recommended Screw Driver	Main Circuit M6
Release	Ekip Dip LS/I
Release Type	EL
Short-Circuit Performance Level	V
Standards	IEC60947-2
Sub-type	XT2
Terminal Connection Type	Front
Terminal Type	Bolt
Tightening Torque	6 N·m

Certificates and Declarations

ATEX Certificate	No certification needed
Data Sheet, Technical Information	SDC210100D0206 1SDC210099D0206
Declaration of Conformity - CE	9AKK106713A5901
GL Certificate	1SDL000163R0093
LR Certificate	1SDL000163R0100
UL Certificate	No certification needed
VDE Certificate	No certification needed
Dimension Diagram	1SDH000721R0100
Mechanical Drawings	1SDH000721R0100
Wiring Diagram	1SDM000068R0001
Instructions and Manuals	1SDH000721R0001

External Classifications and Standards

ETIM 8	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 9	EC000228 - Power circuit-breaker for trafo/generator/installation protection
Object Classification Code	Q
UNSPSC	39120000
WEEE Category	5. Small Equipment (No External Dimension More Than 50 cm)
eClass	V11.1 : 27370409

Categories

Low Voltage Products and Systems → Circuit Breakers → Moulded Case Circuit Breakers → Tmax XT

