Data sheet

6AG1134-3AB00-7AY0



SIPLUS PS UPS1600 10A

SIPLUS PS UPS1600 10A based on 6EP4134-3AB00-0AY0 with conformal coating, -25...+70 $^{\circ}$ C, uninterruptible power supply input: 24 V DC output: 24 V DC/ 10 A

input	
supply voltage at DC rated value	24 V
input voltage at DC	21 29 V
adjustable response value voltage for buffer connection preset	21.5 V
adjustable response value voltage for buffer connection	21 25 V; Adjustable: 21 V, 21.5 V, 22 V, 22.5 V, 23 V, 24 V, 25 V DC
input current at rated input voltage 24 V rated value	14 A; for max. charging current (3 A)
memory	
type of energy storage	with batteries
design of the mains power cut bridging-connection	Adjustable range using rotary coding switch: 0.5 min, 1 min, 2 min, 5 min, 10 min, 20 min, max. buffering time
output	
output voltage	
 in normal operation at DC rated value 	24 V
in buffering mode at DC rated value	24 V
formula for output voltage	Vin - approx. 0.2 V
startup delay time typical	60 ms
voltage increase time of the output voltage typical	60 ms
output voltage in buffering mode at DC	18.5 27 V
output current	
rated value	10 A
 in normal operation 	0 30 A
in buffering mode	0 30 A
peak current	30 A
property of the output short-circuit proof	Yes
design of short-circuit protection	Limitation to 3 x I rated for 30 ms/min; through-conductivity for 1.5 x I rated for 5 sec/min
charging current	0.1 A, 3 A; Automatically depending on battery module
efficiency	
efficiency in percent	
 at rated output voltage for rated value of the output current typical 	97.5 %
in case of operation on rechargeable battery typical	97.5 %
power loss [W]	
 at rated output voltage for rated value of the output current typical 	6 W
in case of operation on rechargeable battery typical	6 W
supplied active power typical	240 W
protection and monitoring	
product function	
 reverse polarity protection against energy storage unit polarity reversal 	Yes

 reverse polarity protection against input voltage polarity reversal 	Yes
display version	
• for normal operation	Normal operation: LED green (OK), floating changeover contact "Bat/OK" to setting "OK" ("OK" means: Voltage of the supplying power supply unit is greater than cut-in threshold set at the DC UPS module); Lack of buffer standby: LED red (alarm), floating changeover contact "Alarm/Bat" to setting "Alarm"; Battery replacement required: LED red (alarm) flashing with approx. 0.25 Hz, floating changeover contact "Alarm/Bat" switching with approx. 0.25 Hz; Energy storage > 85%: LED green (Bat > 85%), floating NO contact "Bat > 85" closed; Permissible contact current capacity: DC 60 V/1 A or AC 30 V /1 A
in buffering mode	Buffered mode: LED yellow (Bat), floating changeover contact "OK/Bat" to setting "Bat"; Prewarning battery voltage < 20.4 VDC: LED red (alarm), floating changeover contact "Alarm/Bat" to setting "Alarm"; Energy storage > 85%: LED green (Bat > 85%), floating NO contact "Bat > 85" closed
interfaces	
product component PC interface	No
product function communication function	Yes
design of the interface	without
safety	Millout
galvanic isolation between input and output	No
operating resource protection class	Class III
protection class IP	IP20
standard	II 20
	EN 55022 Close D
for emitted interference for interference immunity	EN 55022 Class B
for interference immunity	EN 61000-6-2
standards, specifications, approvals	
certificate of suitability	
CE marking	Yes
MTBF at 40 °C	415 574 h
ambient conditions	
ambient temperature	
 in horizontal mounting position during operation 	-25 +70 °C; with natural convection
 during transport 	-40 +85 °C
during storage	-40 +85 °C
installation altitude at height above sea level maximum	6 000 m
ambient condition relating to ambient temperature - air pressure - installation altitude	In case of operation at altitudes of 2000 - 6000 m above sea level: Output power derating of -7.5 %/1000 m or reduction of the ambient temperature by 5 K/1000 m
relative humidity with condensation according to IEC 60068-2-38 maximum	100 %; RH incl. condensation/frost (no commissioning if condensation is present), horizontal installation
chemical resistance to commercially available cooling lubricants	Yes; incl. diesel and oil droplets in the air
resistance to biologically active substances conformity according to EN 60721-3-3	Yes; Class 3B2 mold, fungal, sponge spores (except fauna); class 3B3 upon request
resistance to chemically active substances conformity according to EN 60721-3-3	Yes; Class 3C4 (RH < 75%) incl. salt spray acc. to EN 60068-2-52 (severity level 3)
resistance to mechanically active substances conformity according to EN 60721-3-3	Yes; Class 3S4 incl. sand, dust
resistance to biologically active substances conformity according to EN 60721-3-6	Yes; Class 6B2 mold, fungal, sponge spores (except fauna)
resistance to chemically active substances conformity according to EN 60721-3-6	Yes; Class 6C3 (RH < 75%) incl. salt spray acc. to EN 60068-2-52 (severity level 3)
resistance to mechanically active substances conformity according to EN 60721-3-6	Yes; Class 6S3 incl. sand, dust
coating for equipped printed circuit board according to EN 61086	Yes; Class 2 for high availability
type of coating protection against pollution according to EN 60664-3	Yes; Type 1 protection
type of test of the coating according to MIL-I-46058C	Yes; Discoloration of the coating during service life possible
product conformity of the coating Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A	Yes; Conformal Coating, Class A
connection method	
type of electrical connection	screw terminal
• at input	24 V DC: 2 screw terminals for 0.2 6 mm²/24 13 AWG
• at output	24 V DC: 2 screw terminals for 0.2 6 mm²/24 13 AWG
for rechargeable battery module	24 V DC: 2 screw terminals for 0.2 6 mm²/24 13 AWG
for control circuit and status message	14 screw terminals for 0.2 1.5 mm²/24 16 AWG

mechanical data					
width × height × depth of the enclosure	50 × 139 × 125 mm				
installation width × mounting height	50 × 239 mm	50 × 239 mm			
required spacing					
• top	50 mm				
• bottom	50 mm				
• left	0 mm	0 mm			
right	0 mm				
fastening method	Snaps onto DIN rail EN 60715 3	Snaps onto DIN rail EN 60715 35x7.5/15			
standard rail mounting	Yes				
S7 rail mounting	No	No			
wall mounting	No				
housing can be lined up	Yes				
net weight	0.38 kg				
accessories					
electrical accessories	Battery module				
urther information internet links					
internet link					
to website: Industry Mall	https://mall.industry.siemens.com	m			
to website: Industry Online Support	https://support.industry.siemens				
additional information					
other information	Specifications at rated input volt	Specifications at rated input voltage and ambient temperature +25 °C (unless			
	otherwise specified)	ago ana ambioni tempore	ataro 120 0 (armood		
security information					
	threats, it is necessary to impler state-of-the-art industrial cybers solutions constitute one elemen for preventing unauthorized acc networks. Such systems, machi to an enterprise network or the i necessary and only when appronetwork segmentation) are in ple cybersecurity measures that mawww.siemens.com/cybersecurit undergo continuous developmer recommends that product update	that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)			
Classifications	no longer supported, and failure customer's exposure to cyber th subscribe to the Siemens Indus	tes are applied as soon as ons are used. Use of proce to apply the latest update preats. To stay informed a trial Cybersecurity RSS F	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase bout product updates,		
Classifications	no longer supported, and failure customer's exposure to cyber th subscribe to the Siemens Indus	tes are applied as soon as ons are used. Use of proce to apply the latest update preats. To stay informed a trial Cybersecurity RSS F	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase bout product updates,		
Classifications	no longer supported, and failure customer's exposure to cyber th subscribe to the Siemens Indust https://www.siemens.com/cert. (tes are applied as soon as ons are used. Use of proce to apply the latest update reats. To stay informed a trial Cybersecurity RSS F (V4.7)	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase bout product updates, eed under		
Classifications	no longer supported, and failure customer's exposure to cyber th subscribe to the Siemens Indust https://www.siemens.com/cert. (tes are applied as soon as ons are used. Use of proce to apply the latest update areats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14	lucts and solutions cure. Siemens strongly is they are available duct versions that are es may increase about product updates, eed under Classification 27-04-07-05		
Classifications	no longer supported, and failure customer's exposure to cyber th subscribe to the Siemens Indust https://www.siemens.com/cert. (tes are applied as soon as ons are used. Use of proce to apply the latest update reats. To stay informed a trial Cybersecurity RSS F (V4.7)	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase bout product updates, eed under		
Classifications	no longer supported, and failure customer's exposure to cyber th subscribe to the Siemens Indust https://www.siemens.com/cert. (tes are applied as soon as ons are used. Use of proce to apply the latest update areats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14	lucts and solutions cure. Siemens strongly is they are available duct versions that are es may increase about product updates, eed under Classification 27-04-07-05		
Classifications	no longer supported, and failure customer's exposure to cyber th subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass eClass	tes are applied as soon as ons are used. Use of proce to apply the latest update reats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase bout product updates, eed under Classification 27-04-07-05 27-04-07-05		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass eClass eClass	tes are applied as soon as ons are used. Use of proce to apply the latest update reats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12 9.1	lucts and solutions cure. Siemens strongly is they are available duct versions that are es may increase about product updates, eed under Classification 27-04-07-05 27-04-07-05		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass eClass eClass eClass eClass eClass	tes are applied as soon as ons are used. Use of proce to apply the latest update treats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12 9.1 9 8	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase bout product updates, eed under Classification 27-04-07-05 27-04-07-05 27-04-07-05 27-04-07-05 27-04-07-05		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass eClass eClass eClass eClass eClass eClass eClass	tes are applied as soon as ons are used. Use of proce to apply the latest update increats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12 9.1 9 8 7.1	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase about product updates, leed under Classification 27-04-07-05 27-04-07-05 27-04-07-05 27-04-07-05 27-04-06-90 27-04-06-90		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass	tes are applied as soon as ons are used. Use of proce to apply the latest update ireats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12 9.1 9 8 7.1 6	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase about product updates, eed under Classification 27-04-07-05 27-04-07-05 27-04-07-05 27-04-06-90 27-04-06-90		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass eClass eClass eClass eClass eClass eClass eClass	tes are applied as soon as ons are used. Use of proce to apply the latest update increats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12 9.1 9 8 7.1	lucts and solutions cure. Siemens strongly is they are available duct versions that are es may increase about product updates, eed under Classification 27-04-07-05 27-04-07-05 27-04-07-05 27-04-07-05 27-04-06-90 27-04-06-90		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass	tes are applied as soon as ons are used. Use of proce to apply the latest update ireats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12 9.1 9 8 7.1 6	lucts and solutions cure. Siemens strongly s they are available duct versions that are es may increase ibout product updates, eed under Classification 27-04-07-05 27-04-07-05 27-04-07-05 27-04-06-90 27-04-06-90 27-04-06-90		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass	tes are applied as soon as ons are used. Use of proce to apply the latest update treats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12 9.1 9 8 7.1 6 9	lucts and solutions cure. Siemens strongly is they are available duct versions that are es may increase about product updates, eed under Classification 27-04-07-05 27-04-07-05 27-04-07-05 27-04-06-90 27-04-06-90 EC000382		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass eClass eClass eClass eClass eClass eClass eClass eClass eTlass eTlM ETIM	tes are applied as soon as ons are used. Use of proce to apply the latest update treats. To stay informed a trial Cybersecurity RSS F (V4.7) Version 14 12 9.1 9 8 7.1 6 9 8 7	lucts and solutions cure. Siemens strongly is they are available duct versions that are es may increase about product updates, eed under Classification 27-04-07-05 27-04-07-05 27-04-07-05 27-04-06-90 27-04-06-90 27-04-06-90 EC000382 EC000382		
Classifications	no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Indust https://www.siemens.com/cert. (eClass eClass eClass eClass eClass eClass eClass eClass eClass ETIM ETIM	tes are applied as soon as ons are used. Use of proce to apply the latest update trial Cybersecurity RSS F (V4.7) Version 14 12 9.1 9 8 7.1 6 9 8	lucts and solutions cure. Siemens strongly is they are available duct versions that are es may increase about product updates, eed under Classification 27-04-07-05 27-04-07-05 27-04-07-05 27-04-06-90 27-04-06-90 EC000382 EC000382		

General Product Approval

Miscellaneous

Manufacturer Declaration







loot woodified.	0/04/0004	C 7
last modified:	6/24/2024	۳