Data sheet

6EP3323-0SA00-0BY0



SITOP PSU3600 DUAL/1ACDC/2x15VDC/3.5A

SITOP PSU3600 dual stabilized power supply Input: 120-230 V AC Output: 15 V/3,5 A 2x DC two potential-free outputs

input	
type of the power supply network	1-phase AC or DC
supply voltage at AC	
minimum rated value	120 V
maximum rated value	230 V
• initial value	85 V
• full-scale value	264 V
supply voltage at AC	Derating at < 110 V AC/DC: output power max. 100 W
input voltage at DC	88 250 V
wide range input	Yes
buffering time for rated value of the output current in the event of power failure minimum	10 ms
operating condition of the mains buffering	at Vin = 120 V, 40 ms at Vin = 187 V
line frequency	50/60 Hz
line frequency	47 63 Hz
input current	
 at rated input voltage 110 V 	1.3 A
 at rated input voltage 120 V 	2.2 A
 at rated input voltage 220 V 	0.7 A
at rated input voltage 230 V	1.3 A
current limitation of inrush current at 25 °C maximum	35 A
I2t value maximum	1 A ² ·s
fuse protection type	T 3.15 A (not accessible)
fuse protection type in the feeder	Recommended miniature circuit breaker: 6-10 A characteristic C
output	
voltage curve at output	Controlled, isolated DC voltage
number of outputs	2
output voltage at DC rated value	15 V
formula for output voltage	2 x 15 V DC
output voltage	
 at output 1 at DC rated value 	15 V
at output 2 at DC rated value	15 V
output voltage adjustable	Yes; via potentiometer per output
adjustable output voltage	12 28 V
relative overall tolerance of the voltage	1 %
relative control precision of the output voltage	
on slow fluctuation of input voltage	0.1 %
on slow fluctuation of ohm loading	1 %
residual ripple	
maximum	50 mV

voltage peak	470 V	
• maximum	150 mV	
display version for normal operation	Green LED grün for Vout >10 V (summation display)	
type of signal at output	-	
behavior of the output voltage when switching on	Overshoot of Vout < 1 %	
response delay maximum	0.5 s	
output current		
rated value	3.5 A	
at output 1 rated value	3.5 A	
at output 2 rated value	3.5 A	
rated range	0 3.5 A; Output power max. 60 W per output	
supplied active power typical		
	105 W Yes	
bridging of equipment	2	
number of parallel-switched equipment resources for increasing the power	2	
efficiency		
efficiency in percent	88 %	
power loss [W]		
at rated output voltage for rated value of the output current typical	18 W	
protection and monitoring		
design of the overvoltage protection	≤ 35 V	
property of the output short-circuit proof	Yes	
design of short-circuit protection	Electronic shutdown, automatic restart	
response value current limitation	5 A	
design of the current limitation	depending on the voltage setting	
safety	aspending on the relage county	
	Yes	
galvanic isolation between input and output		
galvanic isolation	Safety extra low output voltage Vout according to EN 60950-1	
operating resource protection class	Class I	
leakage current	25 1	
• maximum	3.5 mA	
protection class IP	IP20	
EMC		
standard	FU 01	
• for emitted interference	EN 55022 Class B	
 for mains harmonics limitation 	EN 61000-3-2	
for interference immunity	EN 61000-6-2	
standards, specifications, approvals		
certificate of suitability		
certificate of suitability • CE marking	Yes	
•	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC	
CE markingUL approval	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310	
CE markingUL approvalCSA approval	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC	
CE markingUL approval	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310	
CE markingUL approvalCSA approval	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; -	
CE markingUL approvalCSA approvalEAC approval	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes	
 CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) 	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes	
 CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310	
 CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate 	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310 No	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability IECEx	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310 No	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability IECEX ATEX ULhazloc approval	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310 No	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability IECEX ATEX ULhazloc approval CCSAus, Class 1, Division 2	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310 No No No No No	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability IECEX ATEX ULhazloc approval CCSAus, Class 1, Division 2 FM registration	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310 No No No	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability IECEX ATEX ULhazloc approval CCSAus, Class 1, Division 2 FM registration standards, specifications, approvals marine classification	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310 No No No No No No	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability IECEX ATEX ULhazloc approval CCSAus, Class 1, Division 2 FM registration standards, specifications, approvals marine classification shipbuilding approval	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310 No No No No No	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability IECEX ATEX ULhazloc approval CCSAus, Class 1, Division 2 FM registration standards, specifications, approvals marine classification shipbuilding approval Marine classification association	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes; according to UL1310 No No No No No No	
CE marking UL approval CSA approval EAC approval Regulatory Compliance Mark (RCM) NEC Class 2 type of certification CB-certificate standards, specifications, approvals hazardous environments certificate of suitability IECEX ATEX ULhazloc approval CCSAus, Class 1, Division 2 FM registration standards, specifications, approvals marine classification shipbuilding approval	Yes; cULus-listed (UL 508, CSA C22.2 No. 107.1), file E197259; outputs NEC Class 2 acc. to UL 1310 Yes; - Yes Yes Yes Yes; according to UL1310 No No No No No No	

Det Norske Veritas (DNV)		No			
Lloyds Register of Shipping (LRS) ambient conditions	No				
ambient conditions					
ambient temperature	05 170 °C. Dorotina > 60°C.	07			
during operation during transport	-25 +70 °C; Derating > 60°C:	: 2%/°K			
during transport		-40 +70 °C			
during storage environmental category according to IEC 60721	Climate class 3K3, 5 95% no	-40 +70 °C			
connection method	Climate class 3K3, 5 95 // fic	Condensation			
type of electrical connection	screw terminal				
at input					
• at output		L1, N, PE: 1 screw terminal each for 0.5 2.5 mm² single-core/finely stranded			
• at output	output for 0.5 2.5 mm²	+: 1 screw terminal per output for 0.5 2.5 mm ² ; -: 2 screw terminals per output for 0.5 2.5 mm ²			
 for auxiliary contacts 	-				
mechanical data					
width × height × depth of the enclosure	42 × 125 × 125 mm				
installation width × mounting height	42 mm × 225 mm				
required spacing					
• top	50 mm				
• bottom	50 mm				
• left	0 mm	0 mm			
• right	0 mm	0 mm			
fastening method	Snaps onto DIN rail EN 60715	Snaps onto DIN rail EN 60715 35x7.5/15			
standard rail mounting	Yes	Yes			
S7 rail mounting	No				
wall mounting	No	No			
housing can be lined up	Yes				
net weight	0.55 kg				
further information internet links					
internet link					
• to website: Industry Mall	https://mall.industry.siemens.co	<u>om</u>			
to website: Industrial communication	https://siemens.com/industrial-o	https://siemens.com/industrial-communication			
• to website: CAx-Download-Manager	https://siemens.com/cax	https://siemens.com/cax			
• to website: Industry Online Support	https://support.industry.siemens	s.com			
additional information					
other information	Specifications at rated input vol	Specifications at rated input voltage and ambient temperature +25 °C (unless			
	otherwise specified)				
security information					
security information	that support the secure operation order to protect plants, syste threats, it is necessary to imple state-of-the-art industrial cybers solutions constitute one element for preventing unauthorized accentworks. Such systems, mach to an enterprise network or the necessary and only when approprietwork segmentation) are in procybersecurity measures that may www.siemens.com/cybersecuri undergo continuous developmenterecommends that product updated and that the latest product vers no longer supported, and failure customer's exposure to cyber the subscribe to the Siemens Industrial	Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)			
Classifications					
		Version	Classification		
	eClass	14	27-04-07-01		
	eClass	12	27-04-07-01		
	eClass	9.1	27-04-07-01		
	eClass	9	27-04-07-01		
	eClass	8	27-04-90-02		

eClass	7.1	27-04-90-02	
eClass	6	27-04-90-02	
ETIM	9	EC002540	
ETIM	8	EC002540	
ETIM	7	EC002540	
IDEA	4	4130	
UNSPSC	15	39-12-10-04	

Approvals Certificates

General Product Approval

Manufacturer Declaration Declaration of Conformity







last modified: 8/28/2024 🖸